



NOTES:
 1. THIS INSTALLATION SHALL COMPLY WITH MFG. INSTRUCTIONS. IN NO CASE SHALL LEAD LENGTHS EXCEED 15 INCHES FROM LOAD-SIDE TERMINAL OF CBI MAIN.
 2. BOND ONLY IF USED AS SERVICE EQUIPMENT.

ONE-LINE DIAGRAM

FOR 7.5HP OR LARGER (1 of 3)

SEWER PANEL 3H

BERKELEY COUNTY WATER AND SANITATION
 POTABLE WATER & SANITARY SEWER STANDARDS
 REVISED 08/28/09

NOT TO SCALE